

Announcement No. 1
supply and assembly of Diesel Generator Set - for RTG crane (the "Tender")
Tender No. 3164/TZ/23

Further to the above Tender published by Ashdod Port Company ("APC"), please find answers to questions regarding the Tender Documents and clarifications:

No.	Page	Item	Questions	ANSWER
1	13	6.1	Prime power: 450kva, 500V, 50HZ: based on on existing engine model:TAD1242GE, the D-G set power rating should be: 400kva@prime power, 440kva@standby power, 50hz; If running at 1800rpm(60hz), it can reach 450kva@prime power; Kindly double check with buyer.	The motor data is as mentioned in para 6.1.1 (352KW prime, 387Kw LTP, 387KW STBY 50hz 1500rpm) Data of alternator: Stamford 450KVA 350KW 500v 1500rpm 3phase
2	13	6.1.1	Enigne model: TAD1242GE already out of Volvo production line. The recommend model is: TAD1344GE-B with: prime power: 354kw, standby power: 389kw;	The requirement of the new DG is as set in paragraph 7 of the specitification
3	14	6.2	PLC: the new version of D-G set controller will be our own professional D-G set controller insteaday of Siemens PLC;	the Siemens PLC is part of the crane not part of the D-G. for the D-G we request controller
4	15	6.4.1.2	For the AD-G(Axuliary D-G set), Does this AD-G are in scopes of replacement? For this function, we have new proposal to use main D-G set running 900rpm to generate power to supply through a power converter system. Can proposal to the buyer?	Paragraph 6 introduce existing equipment on the crane. The SOW of this tender does not require auxiliary D-G
5	17	7.4.1.1	Which brands do you think the buyer prefer? Or can we proposal based on price priority?	The brands as mention in para. 7.4.1.1
6	20	7.4.2	The stamford alternator we proposal will based on Stamford Chinese factory.	Stamford china can be approved as long as it is following required standards of the specification
7	22	7.4.3.5	For the automatic fire suppression system, do you have more information or can provide existing installed on RTGC of this terminal?	Existing RTG don't have fire suppression on the D-G. we request DAFO , Fogmakker or equivalent
8	23	10	For the warranty, due to engine manufacturer's gobal warranty policy, the warranty period will be: 12 months with unlimited engine running hours; OR: 24 months or 3000 engine running hours, subject to earlier come conditions. The warranty extend should be get from engine manufacturer local service provider, we can't extend at our side; For other items beside of engine, can follow the warranty period requirement;	Warranty shall be period of 24months or 8400 engine hours.
9		Others	It's 3+13 project, how to price those 13 sets options which are expecting to finished in 5 years?	The price of the options is as mention in para 1.3 of the IFP
10		Others	Payment: Our payment to our agent as your required 30% downpayment, 70% covered by LC;	The terms of payment is as written in paragraph 10 of the agreement.
11		Others	For supply scopes: Our scopes will be: D-G manufacturing, sea delivery, site commissioning and training, other scopes will be your side;	The delivery of the D-G is as set in the agreement