

April 4, 2024

Dear Sirs,

**Announcement No. 3**  
**Tender for the supply and assembly of Diesel Generator Set - for RTG crane - (the "Tender")**  
**Tender No. 3164/TZ/23**

Further to the announcement made on January 25, 2024 (the "**Original Announcement**") with respect to the Tender, Ashdod Port Company ("**APC**") wishes to inform of amendments to the Original Announcement, as follows:

1. **paragraph 7.4.3** of the specification shall be updated as follows:

Required outer dimension shall not exceed **Length<= 3700mm, Width<=1500mm, Height<=2100mm**

2. **paragraph 7.4.3.1** of the specification shall be updated as follows:

**7.4.3.1. Noise level:**

The noise in the surrounding of the D-G set, with closed doors, shall not exceed the following levels

- **100 kw at 1 meter's distance - ~90 dB(A)** - similar to existing genset noise levels

1. All other provisions included in the Original Announcement remain the same.

**Please sign and submit this Announcement within your Technical Proposal to be submitted with respect to the Tender.**

Sincerely,

Orit Cohen

Secretary of the Tender Committee

Cc: Members of the Tender Committee

---

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature and Stamp